



FIRE ALARM NFPA 72 CHECKLIST

GENERAL REQUIREMENTS

1. Provide a minimum of three sets of plans for review and approval
2. Ensure all items below are provided on the plans.

REQUIREMENTS ON PLANS

1. Owner/project name
2. Project street address, city, building number (if applicable)
3. Contractor name, address, phone number and license number
4. Scaled or fully dimensioned drawings
5. Point of compass
6. Square footage of area(s) to be permitted
7. Scope of work summary
8. Occupancy class and/or use of each room
9. Rooms are labeled and room dimensions are provided
10. Equipment symbol legend
11. Type of alarm circuit wire to be used (class A or B) style
12. Number and type of devices being installed
13. Location of devices being installed
14. Location and mounting heights of any and all devices being installed
15. Location of fire alarm control panel (FACP)
16. Sectional views of structure, roof, ceiling, rooms with beam or solid joist and drop ceilings, etc to be illustrated unless the building has smooth ceiling
17. Single line and point to point wiring diagrams
18. Zones identified

ADDITIONAL REQUIREMENTS

1. Provide cut sheets for all equipment listed for use

These are the minimum requirements. Additional requirements maybe apply upon plan submittal/review.

Inspections shall include rough and final. No wiring shall be covered prior to an inspection and approval. Inspections shall be scheduled a minimum of 72 hours in advance.